



EU DECLARATION OF CONFORMITY

As per Directive 2014/34/EU ATEX, we:

Kaustubha Udyog (Orion Instruments), Pune, India

Office:

7, Parichaya Society, 1000/ 6 D,
Navi Peth,
Pune - 411 030 Maharashtra, India
Phone : +91-20-24532124

Factory:

S. No. 36/1/1, Sinhgad Road,
Vadgaon Khurd,
Pune - 411 041 India
Phone: +91-20-24393877
E-mail: ku.pressure@gmail.com

Declare that the product:

'FC Series Flameproof switch' Bulletin no. KA121024 (Orion Instruments brand)
fulfills the Provisions of the Directive.

Marking:

 **II 2 GD; Ex db IIC T6 Gb, Ex tb IIIC T85°C Db (-20°C ≤ Ta ≤ +60°C) IP66**

Notified Body for EU-Type Examination: SGS Fimko Oy (no. 0598)

EU-type Examination Certificate: Baseefa07ATEX0268X/4 issued 29th May 2019

IECEx Certificate of Conformity : IECEx BAS 07.0096X Issue No 04 Dt. 29th May 2019

Notified Body for Quality Systems: SGS Fimko Oy (no. 0598)

Harmonised Standards used:

EN IEC 60079-0:2018 EN 60079-1:2014 EN 60079-31:2014

Other Standards and Specifications used:

IEC 60079-0:2017 (Edition 7)

IEC 60079-1:2014 (Edition 7) IEC 60079-31:2013 (Edition 2)

ISO 9001:2015 & BS EN ISO/IEC 80079-34:2011 standards are used to prove the product's conformity with the requirements.

On behalf of the above named company, I declare that, on the date the product accompanied by this declaration is made available on the market, the product conforms with all technical and regulatory requirements of the above listed directive.

Ravi Moholkar, CEO

Date: 06-06-2019

(Rev 02 - Year of publication of Standards updated, Notified body SGS Baseefa changed to SGS Fimko Oy)



Kaustubha Udyog (Orion Instruments)

Registered Office :

7, Parichaya Society, 1000/6D, Navi Peth, Pune 411 030 INDIA
Tel.: +91-(0) 20-24532124 / 24531053
Telefax : +91-(0) 20-25460486 / 24532124

Marketing Office :

S. No. 36/1/1, Sinhgad Road, Vadgaon Khurd,
Pune 411 041 INDIA
Tel.: +91-(0) 20-24393877
Telefax : +91-(0) 20-24393577 / 25460486

Certificate No.: FM72815

